Utah Department of Environmental Quality Division of Drinking Water

Public Water System Inventory Report

Run Date: 08/04/2011 12:21 pm

PWS ID: UTAH18043 Name: SPRING GLEN WATER COMPANY

Legal Contact SPRING GLEN WATER COMPANYXXX Rating: Approved

LARRY A HALL Rating Date: 05/10/1999

Address: 89 West Monarch Drive Activity Status: Active

BOUNTIFUL, UT 84010

Phone Number: 801-209-6382

City Served (Area):
County: SALT LAKE COUNTY

Gal/Day Gal/Min

System Type:CommunityLast Inv Update:01/05/2011Avg Daily Prod:Activity Status Cd:ActiveLast Snty Srv Dt:09/30/2010Total Dsgn Cap:Population:50Surveyor:JOHN H OAKESONTotal Emerg Cap:

Oper Period: 1/1 to 12/31

Contacts

Contact			Phone Numbers							
Type Name		Title	Office	Emergency	Email Address					
AC	HALL, LARRY A	MANAGER	801-209-6382	435-843-7509	larryh@aquaenviron.com					

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections	
Residential	Unmetered	0	15	
			15 T c	tal Svc Connections

Storage

Total Storage: 60,000 GAL Number of Units: 1 Adequate Capacity: NO

		_		Constr Matrl	Overflow Elev	Activity Status	
No.	Name	Туре	Effective Volume	Matri	Elev	Status	Press'd
ST001	STORAGE FACILITY ST001	Ground	60,000 GAL	Concrete		Α	

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Process
TP001	MAIN WELL (#1) CHLORINATOR		A	

Distribution System

Pump Type	Total Dyn Head	Pressure	Cross	Auhority
	ft H2O P.S.I.	Adequate	Connection	Statement
		No		

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	MAIN WELL (#1)	Active	WL	6	35 GPM		Yes	GW	Permanent	1/1 to 12/31	
WS002	WELL 2 (STNDRY)	Inactive	\/\I	4	15 GPM		Nο	GW	Other		

^{*}Reports measured flow for wells, approved design capacity for all other sources.